



For inspection call  
Tyler Edde (931) 619-2983  
John Freeman: (931) 703-3173

Only inspect between  
7:30 AM- 3:30 PM

# Service Line Inspection

Minimal 2hr notice for Service Line Inspections

PASS\_\_\_\_\_ FAIL\_\_\_\_\_

## Contractor/Owner Information

Contractor: \_\_\_\_\_ Owner: \_\_\_\_\_

Address (location) \_\_\_\_\_  
*Street Address*

Contact # ( ) \_\_\_\_\_ Permit # \_\_\_\_\_

Permit type : \_\_\_\_\_  
New construction: Water / Sewer      Repair / Replace : existing service : Water / Sewer

## SEWER SPECIFICATIONS

### Pipe size

- 4" residential     6" industrial, commercial

\*\*\*No thin wall pipe is permitted to be used. Schedule 40, 26, or 35 are acceptable

**\*\*BOTH WATER AND SEWER SERVICES ARE TO BE SLEEVED OR INSTALLED 18" DEEP PRIOR TO FOOTING BEING POURED\***

### Work Criteria

- |  |  |   |
|--|--|---|
| <input type="checkbox"/> Minimum 18" depth (dirt)      | <input type="checkbox"/> Cleanout 18"- 5' from structure | <input type="checkbox"/> Single sweep cleanout at ROW   |
| <input type="checkbox"/> Minimum 30" depth ( asphalt ) | <input type="checkbox"/> Minimum of 1% or 1/8" per ft.   | <input type="checkbox"/> No 90 degree fittings          |
| <input type="checkbox"/> Cleanouts every 75' apart     | <input type="checkbox"/> ¾"(.57) stone bedding for pipe  | <input type="checkbox"/> All cleanouts shall have boxes |
| <input type="checkbox"/> <b>HARDBACK FERNCO ONLY</b>   | <input type="checkbox"/>                                 | <input type="checkbox"/>                                |

\*\* full replacement Yes / No

Notes: \_\_\_\_\_

\*\* All pipes under parking lots or driveway must be backfilled with gravel      Yes / No

\*\* All cleanouts must be recessed with boxes covering them, cleanouts in driveways must be traffic bearing      Yes / No

## WATER SPECIFICATIONS

- |  |  |   |
|--|--|---|
| <input type="checkbox"/> PEX _____         | <input type="checkbox"/> PVC _____               | <input type="checkbox"/> Copper _____               |
| <input type="checkbox"/> Minimum 18" cover | <input type="checkbox"/> Pressure reducing valve | <input type="checkbox"/> Shut/off valve after meter |

Signature: \_\_\_\_\_ Date: \_\_\_\_\_

\*\*\*Notes on the back\*\*\*